

**Schena, Cristeen**

---

**From:** Aram Varjabedian <avarjabedian@woodardcurran.com>  
**Sent:** Saturday, June 16, 2018 1:09 PM  
**To:** tberardinelli@town.hull.ma.us; Bill Boornazian; david.burns (david.burns@state.ma.us); Jim Dow; Frank Cavaleri; jstruzziery@town.hull.ma.us; jsullivan (jsullivan@town.hull.ma.us); kbornheim (kbornheim@town.hull.ma.us); Krahforst, Chris (ckrahforst@town.hull.ma.us); Lemnios, Philip (plemnios@town.hull.ma.us); coconnor@town.hull.ma.us; Robert Scott; Turin, David; Joyce, Ryan (FWE) (ryan.joyce@state.ma.us)  
**Subject:** RE: Hull MA0101231 - SSO Notification Report - Pump Station LS A - 42 Valley beach Ave., Hull, MA  
**Attachments:** SSO\_Notification\_report\_061618\_for\_061218\_42ValleyBeachRd\_LS\_A.pdf

Good afternoon:

Please find the completed SSO Notification Report for the Pump Station LS A [42 Valley Beach Rd.] incident that occurred on 6/12/18. Should you need any additional information, please let me know.

Sincerely,

Aram

Aram Varjabedian  
Plant Manager  
Hull Wastewater Treatment Facility  
1111 Nantasket Avenue | Hull, MA 02045  
Phone 781.925.0906 | Fax 781.925.3056 | Cell 339.214.8334  
[www.woodardcurran.com](http://www.woodardcurran.com)



COMMITMENT & INTEGRITY DRIVE RESULTS

---

**From:** Aram Varjabedian  
**Sent:** Wednesday, June 13, 2018 9:32 AM  
**To:** Aram Varjabedian <avarjabedian@woodardcurran.com>; Berardinelli, Terri <tberardinelli@town.hull.ma.us>; Bill Boornazian <wboornazian@woodardcurran.com>; david.burns (david.burns@state.ma.us) <david.burns@state.ma.us>; Dow, James (jdow@town.hull.ma.us) <jdow@town.hull.ma.us>; Frank Cavaleri <fcavaleri@woodardcurran.com>; jstruzziery (jstruzziery@town.hull.ma.us) <jstruzziery@town.hull.ma.us>; jsullivan (jsullivan@town.hull.ma.us) <jsullivan@town.hull.ma.us>; kbornheim (kbornheim@town.hull.ma.us) <kbornheim@town.hull.ma.us>; Krahforst, Chris (ckrahforst@town.hull.ma.us) <ckrahforst@town.hull.ma.us>; Lemnios, Philip (plemnios@town.hull.ma.us) <plemnios@town.hull.ma.us>; O'Connor, Carol <coconnor@town.hull.ma.us>; Robert Scott (rscott@woodardcurran.com) <rscott@woodardcurran.com>; Turin, David (Turin.David@epa.gov) <Turin.David@epa.gov>; Joyce, Ryan (FWE) (ryan.joyce@state.ma.us) <ryan.joyce@state.ma.us>  
**Subject:** Hull MA0101231 - SSO Preliminary Notification - Pump Station A - 42 Valley beach Ave., Hull, MA

Good morning:

This email is to inform you of a small release of sewage at Pump Station A yesterday at approximately 9:00 AM. A two-person crew was at the pump station performing valve exercising as part of scheduled preventive maintenance. In the process of exercising the 2-

inch drain-back bypass valve, sewage started coming out of the valve box and leaking onto the ground and asphalt areas adjacent to the station.

Immediately the staff called for additional assistance, and was able to channel the flow towards the adjacent wet well [2 feet away] limiting the spread of a lot of the wastewater away from the station. It is estimated that less than 50 gallons made it out onto the ground and the adjacent asphalt area and road surface.

The release was stopped approximately 30 minutes later, when the drain valve was isolated. The released liquid evaporated quickly, and the all areas were treated with lime very quickly for disinfection. A plan for repair of the broken valve was developed and is scheduled for repair today.

A complete SSO notification report will follow. Should you have any questions or concerns, please let me know.

Sincerely,

Aram

Aram Varjabedian  
Plant Manager  
Hull Wastewater Treatment Facility  
1111 Nantasket Avenue | Hull, MA 02045  
Phone 781.925.0906 | Fax 781.925.3056 | Cell 339.214.8334  
[www.woodardcurran.com](http://www.woodardcurran.com)



COMMITMENT & INTEGRITY DRIVE RESULTS